

Subject: ASTAD's Vendor's Assessment Conclusion for QICC (Qatar International Cables Company)
Date: Friday, December 16, 2011 1:29:59 PM Arabian Standard Time
From: Mustapha Dbouk

From: Manuel Nicolau <nicolau@astad.qa>
Date: Fri, 16 Dec 2011 08:44:37 +0100
To: Melvin Buthello <Melvin.Buthello@qicc-nexans.com>
Cc: Lucie Heidar <lucie.heidar@qicc-nexans.com>, Mustapha Dbouk <mostafa.dbouk@nexans.com>
Subject: ASTAD's Vendor's Assessment Conclusion for QICC (Qatar International Cables Company)

Dear Sir/Madam,

Please be informed that ASTAD has now completed the Vendor's Pre-Assessment Process and we would like to inform you that **QICC (Qatar International Cables Company)** is now part of ASTAD's Preferred Vendors List under the reference **VPAS/024/2011**, for the following scope:

1. Cables and wires that comply with the requirements of QCS Section 21 Part 6, BS7671 and QGEWC requirements. Generally,

- Flexible Cable: BS 6007; BS 6500;
- Low-Voltage cables to IEC 60227, BS 6004, BS 6500 IEC 60502
- Armoured Cable: BS 5467; BS6622
- Cables in Conduit: BS 7211;
- Instrumentation: BS7917, BS 6883; BS 5308;
- High Resistant and High Temperature cable: BS6500; BS 6004, BS6007
- LV Fire Resisting Cable: BS 7917;
- LSZH LV Cable: BS 6724;
- Surface laid Cables (Residential): BS 6004; BS 6346; BS 7211; BS 7629, BS 7889;
- Tri-rated Cables: BS 6231
- Armoured and Un-armoured type to IEC 60502, BS 5467, BS 6004, BS 6622 and BS 6724
- MICC: BS EN 60702-1
- Protec: BS 8436; IS273
- LSZH Medium Voltage: BS 5467; BS 7835
- XLPE/SWA/PVC Medium Voltage: BS 6622

Or other cable types subjected to review and approval.

Cables shall be provided with a type tests certificate from KEMA, ASTA, BASEC or equivalent

2. Cable Accessories purpose manufactured for the above cables;
3. Communication cables complying with EIA/TIA Standards of installation.

Best Regards,

MANUEL NICOLAU
LEAD PROJECT ENGINEER
(Quality Management ASTAD)

T : (974) 4409 6069

E: nicolau@astad.qa



QP / QF J.V.
www.ASTAD.qa

T: (974) 4409 6066
F: (974) 4429 1023

P.O. Box 3212
Doha-Qatar

Towards zero emissions, please consider the environment before printing this email. ASTAD support conservation.

PRIVACY AND CONFIDENTIALITY NOTICE

This e-mail and any files transmitted with it are strictly confidential and intended solely for the person or organization to whom it is addressed. If it comes to the attention of any other unauthorized person, no action may be taken on it nor should it be copied or shown to any third party. If you have received this e-mail in error, please e-mail the sender by replying to this message and delete the original and any printout thereof. Recipient should check this e-mail and any attachment for the presence of viruses. ASTAD Engineering Consultancy and Project Management (ASTAD) shall not be liable for any damage caused by any virus transmitted by this e-mail.