

# Type test Certificate of Complete type test

## QICC

Doha, Qatar

has successfully passed the type test sequence on an

## Thee-core power cable

Type: CU/S.C./XLPE/S.C/CU wires/PVC/SWA/PVC

Rating: 6,35 / 11 (12) kV – 3x240 mm<sup>2</sup>

The test object passed the required clauses of

## IEC 60502-2

The test results are recorded in Certificate No.

## TIC 1019-11

This Certificate is issued on 3 May 2011

KEMA Nederland B.V.



S.A.M. Verhoeven

Director Testing, Inspections & Certification The Netherlands

Copyright © KEMA Nederland B.V.

Please note that this document has been issued for information purposes only, and that the original bound and sealed paper copy of the Certificate including the results of the tests of the apparatus will prevail. This document does not imply that KEMA has certified or approved any apparatus other than the specimen tested.

