



REPORT OF PERFORMANCE

TIC 1507-11

OBJECT multi-core power cable

TYPE 0,6/1 kV, CU/XLPE/PVC/SWA/PVC 4x4 mm²+4x2cx1,5 mm²

MANUFACTURER QICC
Doha, Qatar

CLIENT QICC
Doha, Qatar

TESTED BY KEMA HIGH-VOLTAGE LABORATORY
Arnhem, The Netherlands

DATE OF TESTS 1 April 2011 until 19 July 2011

TEST PROGRAMME Type tests in accordance with IEC 60502-1 (2004) including Amendment 1 (2009)

SUMMARY AND CONCLUSION The object passed the tests.

This Report of Performance applies only to the object tested. The responsibility for conformity of any object having the same designations with that tested rests with the Manufacturer.

This report consists of 31 pages in total.

© Copyright: Only integral reproduction of this report is permitted without written permission from KEMA. Electronic copies in e.g. PDF-format or scanned version of this report may be available and have the status "for information only".
The sealed and bound version of the report is the only valid version.

KEMA Nederland B.V.

S.A.M. Verhoeven
Director Testing, Inspections &
Certification The Netherlands

Arnhem, 3 August 2011